Certificate of Compliance

Certificate Number **20110125 – E52096**
Report Reference **E52096, 1997 July 12**
Issue Date **2011 January 25**

Underwriters Laboratories Inc.®

Issued to:

EATON

1000 CHERRINGTON PKY
MOON TOWNSHIP, PA 15108 USA

This is to certify that representative samples of

Low-voltage AC Power Circuit Breakers

Model Descriptions: Low Voltage AC Power Circuit Breakers - Type Magnum DS Low Voltage AC Power Circuit Breakers rated 4000A, 5000A and 6000A.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

The basic standards used to investigate products in this category are UL 1066, "Low-Voltage AC and DC Power Circuit Breakers Used in Enclosures," ANSI/IEEE C37.13, "Standard for Low-Voltage AC Power Circuit Breakers Used in Enclosures," ANSI/NEMA C37.50, "Switchgear - Low Voltage AC Power Circuit Breakers Used in Enclosures - Test Procedures" and CSA-C22.2 No. 31-1989, "Switchgear Assemblies."

Additional Information: (Cont.)

Ratings.

			Short Circuit Ratings (V Ac)			Short Time Current Ratings		
Circuit Breaker Type	Frame Size Amps	Poles	635	508	254	635	508	254
MDSC40	4000	3, 4	100kA	100kA	100kA	100kA	100kA	100kA

Certificate of Compliance

Underwriters Laboratories Inc.®

Additional Information: (Cont.)

Ratings.

			Short Circuit Ratings (V Ac)			Short Time Current Ratings		
Circuit Breaker Type	Frame Size Amps	Poles	635	508	254	635	508	254
MDSE40	4000	3, 4	100kA	150kA	150kA	100kA	100kA	100kA
MDN840	4000	3 ,4	65 kA	85 kA	85 kA	65 kA	85 kA	85 kA
MDNC40	4000	3, 4	65 kA	100kA	100kA	65 kA	100kA	100kA
MDSC50	5000	3, 4	100kA	100kA	100kA	100kA	100kA	100kA
MDSE50	5000	3, 4	100kA	150kA	150kA	100kA	100kA	100kA
MDSC60	6000	3, 4	100kA	100kA	100kA	100kA	100kA	100kA
MDSE60	6000	3, 4	100kA	150kA	150kA	100kA	100kA	100kA
MDSX40	4000	3	---	200kA	200kA	---	50 kA	50 kA
MDSX50	5000	3	---	200kA	200kA	---	50 kA	50 kA
MDDX40	4000	3, 4	100kA	200kA	200kA	100kA	100kA	100kA
MDDX50	5000	3, 4	100kA	200kA	200kA	100kA	100kA	100kA
MDDX60	6000	3, 4	100kA	200kA	200kA	100kA	100kA	100kA

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers: c UL us the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs
Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at http://www.ul.com/global/eng/pages/corporate/contactus/