Certificate of Compliance

Certificate Number **20110304 – E57335A**
Report Reference **E57335, 2004 September 07**
Issue Date **2011 March 04**

Underwriters Laboratories Inc.®

Issued to: **EATON**

1000 CHERRINGTON PKY
MOON TOWNSHIP, PA 15108 USA

This is to certify that representative samples of **Low-voltage AC Integrally-fused Power Circuit Breakers**

Model Descriptions: Low voltage AC integrally fused power circuit breaker Type MDSL08 rated 800A maximum.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **The basic standards used to investigate products in this category are UL 1066, "Low-Voltage AC and DC Power Circuit Breakers Used in Enclosures," ANSI/IEEE C37.13, "Standard for Low-Voltage AC Power Circuit Breakers Used in Enclosures," and ANSI/NEMA C37.50, "Switchgear - Low Voltage AC Power Circuit Breakers Used in Enclosures - Test Procedures."**

Additional Information: **Ratings:**

Limiters (Amperes)	Maximum Long Time Trip Settings (Amperes)
MA250	200
MA300	240
MA400	320
MA600	480
MA800, MC800	640
MC100	800
MB1200, MC1200	800
MB1600, MC1600	800
MB2000, MC2000	800
MD2500	800
MD3000	800

Voltage: 600 Vac maximum.

Certificate of Compliance

Additional Information: **Ratings:**

Breaker Type	Frame Size (Amperes)	Sensor Rating (Amperes)	Trip Range (Amperes)
MDSL08	800	200	88-220
		250	110-275
		300	132-330
		400	176-440
		600	264-660
		800	352-880

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.
Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at http://www.ul.com/global/eng/pages/corporate/contactus/