Certificate of Compliance

Certificate Number **20110304 – E57335C**
Report Reference **E57335, 2004 September 09**
Issue Date **2011 March 04**

Underwriters Laboratories Inc.®

Issued to: **EATON**

1000 CHERRINGTON PKY
MOON TOWNSHIP, PA 15108 USA

This is to certify that representative samples of **Low-voltage AC Integrally-fused Power Circuit Breakers**

Model Descriptions: Low voltage AC integrally fused power circuit breaker Type MDSL20 rated 2000A maximum.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **The basic standards used to investigate products in this category are UL 1066, "Low-Voltage AC and DC Power Circuit Breakers Used in Enclosures," ANSI/IEEE C37.13, "Standard for Low-Voltage AC Power Circuit Breakers Used in Enclosures," and ANSI/NEMA C37.50, "Switchgear - Low Voltage AC Power Circuit Breakers Used in Enclosures - Test Procedures."**

Additional Information: **Ratings:**

Limiters (Amperes)	Maximum Long Time Trip (Amperes)
MD2500	1500
MD3000	1600
MD3000*	2000*

*** - when supplied with heat sinks.**

Voltage: 600 Vac maximum.

Certificate of Compliance

Underwriters Laboratories Inc.®

Additional Information: **Ratings:**

Breaker Type	Frame Size (Amperes)	Sensor Rating (Amperes)	Trip Range (Amperes)
MDSL20	2000	1600	704-1760
		2000	880-2200

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs
Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at http://www.ul.com/global/eng/pages/corporate/contactus/