# CERTIFICATE OF COMPLIANCE

| | |
|---|---|
| **Certificate Number** | 20130816 – E7819 |
| **Report Reference** | E7819 - 19910906 |
| **Issue Date** | 2013-August-16 |
| **Issued to:** | EATON<br>1000 CHERRINGTON PKY<br>MOON TOWNSHIP, PA 15108 USA |
| **This is to certify that representative samples of** | Arc-fault Circuit Interrupters, Branch/Feeder Type<br>Molded case circuit breakers, Types GHB, GHC, GD, GDB, ECB, GI, HGHB, HGHC, GPS, GHB-HID, and GHC-HID. (See following page for additional model information.)<br><br>Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate. |
| **Standard(s) for Safety:** | ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures." |
| **Additional Information:** | See the UL Online Certifications Directory at www.ul.com/database for additional information |

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

William R. Carney

**William R. Carney, Director, North American Certification Programs**

**UL LLC**

**Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus**

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130816 – E7819
**Report Reference** E7819 - 19910906
**Issue Date** 2013-August-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

**Ratings:**

| Types | Poles | V ac | V dc (+) |
|---|---|---|---|
| | | | |
| GHB/GHC | 1 | 277 | 125 |
| GHB/GHC | 2 | 277/480 | 125/250 |
| GHB/GHC | 3 | 277/480 | 125/250 |
| GD | 3 | 480 | 125/250 |
| GD (++) | 2 | 480 | 125/250 |
| GDB(++) | 2 | 480 | 125/250 |
| GDB | 3 | 480 | 125/250 |
| ECB | 3 | 480 | 125/250 |
| GI(+++) | 3 | 240 | - |
| GI(+++) | 3 | 277/480 | - |
| HGHB(++++) | 1 | 277 | 125 |
| HGHC(++++) | 1 | 277 | 125 |
| GHB-HID(+++++) | 1 | 277 | - |
| GHC-HID(+++++) | 1 | 277 | - |
| GPS | 3 | 480 | - |

(+) - 70 A maximum for single pole, 100 A for 2-pole.
(++) - 15 through 50 A only for 2-pole breaker.
(+++) - 15 through 60 A only.
(++++) - 15 through 30 A only.
(+++++) - 15 and 20 A only.

William R. Carney

**William R. Carney, Director, North American Certification Programs**

**UL LLC**

**Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus**