CERTIFICATE OF COMPLIANCE

Certificate Number	20130123 – E7819
Report Reference	E7819 - 19771102
Issue Date	2013-January-23

Issued to:	EATON 1000 Cherrington PKY Moon Township, PA 15108 USA
This is to certify that representative samples of	Circuit Breakers, Molded Case and Circuit-breaker Enclosures Molded case circuit breakers, Class CTL, Quicklag Types BA, BQL, QBHW, HBAX, HBAW, and HQP, QPHW, QHPX, QHPW, and QC, QCHW, QHCX, QHCW, and BR, BRH, BRHH, BRX. (See following page for additional model information.) Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures."
Additional Information:	See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: with the word “LISTED”; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

William R. Carney

William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

CERTIFICATE OF COMPLIANCE

Certificate Number 20130123 – E7819
Report Reference E7819 - 19771102
Issue Date 2013-January-23

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Ratings:

These are 2, 3 and 4-pole circuit breakers rated 15-100 A, 240 V ac and 1-pole rated 15-30 A, 120/240 V ac, 65,000 AIC and 1-pole rated 15-70 A, 120/240 V, 42,000 AIC and 2-pole rated 15-125 A, 120/240 V, 42,000 AIC.

Type	Interrupting Capacity, A, V ac	Ratings, A
B Q L	10,000 at 240	15-100
HQP/BR	10,000 at 240	15-100
QC	10,000 at 240	15-100
BA	10,000 at 240	15-100
QPHW/BRH	22,000 at 240	15-100
QBHW	22,000 at 240	15-100
QCHW	22,000 at 240	15-100
QHPX/BRHH	42,000 at 240, 120/240	15-125
HBAX	42,000 at 240, 120/240	15-125
QHCX	42,000 at 240, 120/240	15-100
QHPW	65,000 at 240	15-20
HBAW	65,000 at 240	15-20
QHCW	65,000 at 240	15-20
QHPW	65,000 at 120/240	15-30
HBAW	65,000 at 120/240	15-30
QHCW	65,000 at 120/240	15-30

William R. Carney

William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus