# Certificate of Compliance

Certificate Number **20110614 – E45310**
Report Reference **E45310, 1992 November 30**
Issue Date **2011 June 14**



Underwriters Laboratories Inc.®

*Issued to:* **EATON**

**1000 CHERRINGTON PKY**
**MOON TOWNSHIP, PA 15108 USA**

*This is to certify that representative samples of*

## Circuit Breaker and Ground-fault Circuit Interrupters

**Model Descriptions: Circuit Breaker and Ground Fault Circuit Interrupters: Type QCGF, GFCB, GFCBC, QPGF, QBGF, QCHGF, GFCBH, QPHGF and QBHGF.**

*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* **ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures"**
**ANSI/UL 943, "Ground-Fault Circuit-Interrupters"**

*Additional Information:* **Ratings:**

| Type | Poles | Interrupting Capacity A, Vac | Ratings, A |
|---|---|---|---|
| QCGF, GFCBC, GFCB, QPGF, QBGF | 1 pole | 10,000 at 120 | 10-50 |
| QCHGF, GFCBH, QPHGF, QBHGF | 1 pole | 22,000 at 120 | 10-30 |
| QCGF | 2 pole | 10,000 at 120/240 | 10-50 |
| QCGFH, GFCBH, QPGFH, QBGFH | 2 pole | 22,000 at 120/240 | 15-30 |
| GFCB, QPGF, QBGF | 2 pole | 10,000 at 120/240 | 15-60 |

**Only those products bearing the UL Listing Mark for Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate Canadian requirements.**

**The UL Listing Mark for Canada includes: the UL Mark for Canada: c UL with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier in English, French, or English/French) as indicated in the appropriate UL Directory.**

**Look for the UL Listing Mark on the product**

**William R. Carney**
**Director, North American Certification Programs**

Underwriters Laboratories Inc.
Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at http://www.ul.com/global/eng/pages/corporate/contactus/