CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1848770 (LR 43556) **Master Contract:** 163545

Project: 2452446 **Date Issued:** January 24, 2012

Issued to: **Eaton Corporation**

1000 Cherrington Pkwy
Moon Township, PA 15108
USA
Attention: Lou Grahor

The products listed below are eligible to bear the CSA Mark shown

Steve Jeffrey

Issued by: Steve Jeffrey

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Circuit breakers, moulded case type, F-frame, Series C, Type HFD, 15-150A, 1 pole, 15-225A, 2-4 pole, 600V ac and less; 2-4 pole, 250V dc and less; 1-pole, 125V dc and less. Type HFDDC, 15-225A, 3-pole, 600V dc max. Type Fi:, 15-200A, 480 Vac, 2,3 & 4 pole, Type FDE, HFDE, 15- 225A, 600Vac, 3-pole;Type FDMP and HFDMP,40-205A,600Vac and less,3-pole.

Notes:

These circuit breakers may be marked with the following interrupting ratings:

Type	Poles	Frequency, HZ	240V ac	480V ac	600V ac	125V dc	250V dc
HFD	1	50/60	-	-	-	10	-
HFD	2, 3, 4	50/60	100	65	25	-	22
Fi	2, 3, 4	50/60	25	14	-	-	10
FDMP	3	50/60	65	35	18	-	-
HFDMP	3	50/60	100	65	25	-	-
FDE	3	50/60	65	35	18	-	-

HFDE	3	50/60	100	65	25	-	-

*HFDDC – 1 pole, 15-150A, 125V dc/42kA. *HFDDC – 2 poles in series, 15A-225A, 250V dc/50kA.

*HFDDC – 3 poles in series, 15A-225A, 600V dc/42kA

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 5-09 - Moulded Case Circuit Breakers