


NOTE:

- 1. ALL UNITS ARE DESIGNED IN ACCORDANCE WITH APPLICABLE NEMA, UL, ANSI, AND IEEE STANDARDS.
- 2. DRY-TYPE VENTILATED, CLASS AA, NEMA TYPE 2 ENCLOSURE.
- 3. FOR NEMA 3R OUTDOOR APPLICATION, USE WEATHERSHIELD # WS-39.
- 4. TRANSFORMERS ARE FLOOR MOUNTED.
- 5. 220°C CLASS INSULATION SYSTEM.
- 6. PAINT COLOR IS ANSI #61.
- 7. ALUMINUM UNITS HAVE ALUMINUM WINDINGS AND TERMINATIONS. COPPER UNITS HAVE COPPER WINDINGS AND TERMINATIONS.

REF. DWG. NO. 42-5203



DIMENSIONS IN INCHES (mm)

FRAME	A	B	C	D	E	F	G	H	J	K
FR914D	39.00(991)	29.00(737)	22.00(559)	27.00(686)	16.00(406)	2.55(65)	1.25(32)	.50(13)	2.10(53)	.90(23)
	L	M	N	P	Q	R	S	T	U	V
	4.00(102)	8.61(219)	1.83(46)	7.70(196)	5.37(136)	8.50(216)	5.00(127)	4.25(108)	24.66(626)	20.00(508)

REV. 5 EC9-067117 J.C.S./C.B./A.N.

Rev 5. - JUN-14

DRAFTER H.GLEZ	DATE 2/8/2010	MODEL FILENAME V75E001.iam	MODEL REV 5	EATON CORPORATION - CONFIDENTIAL AND PROPRIETARY
ENGINEER C.BADILLO	DATE 2/8/2010	ENGINEERING CHANGE NOTICE NO.		<p>THIS DOCUMENT, INCLUDING THE DRAWING AND INFORMATION CONTAINED THEREON, IS CONFIDENTIAL AND IS THE EXCLUSIVE PROPERTY OF EATON CORPORATION, AND IS MERELY ON LOAN AND SUBJECT TO RECALL BY EATON CORPORATION AT ANY TIME. BY TAKING POSSESSION OF THIS DOCUMENT, THE RECIPIENT ACKNOWLEDGES AND AGREES THAT THIS DOCUMENT CANNOT BE USED IN ANY MANNER ADVERSE TO THE INTERESTS OF EATON, AND THAT NO PORTION OF THIS DOCUMENT MAY BE COPIED OR OTHERWISE REPRODUCED WITHOUT THE PRIOR WRITTEN CONSENT OF EATON CORPORATION. IN THE CASE OF CONFLICTING CONTRACTUAL PROVISIONS, THIS NOTICE SHALL GOVERN THE STATUS OF THIS DOCUMENT.</p>
MFG. ENG.	DATE	UNLESS SPECIFIED TOLERANCES PER		
NEXT ASSY		<p>A</p>	TITLE	
TOOL REF.			<p>DRY TYPE TRANSFORMER OUTLINE</p>	
REFERENCE	SCALE 1-1	PROJECT NO.	DWG NO. FR914D	
SHOP/GENERAL ORDER NO.	TITLE BLOCK REV - 4	PRODUCT TRANSFORMER	PARTS LIST FR914D	
			SHEET 1 OF 1	REV 5