IQ150

Category	Modbus TCP Register	Description	Register Count	Type ID	Units	Writable	Possible Values
System ID	1032	Vendor Name	32	ASCII	no-units		
	1064	Model Name	32	ASCII	no-units		
	1096	Display Name	32	ASCII	no-units		
	1128	Device Type	32	ASCII	no-units		
	1192	Device ID	32	ASCII	no-units		
	1276	Serial Number	32	ASCII	no-units		
	2108	Software Version	24	ASCII	no-units		
	1605	Field Replaceable Unit	1	UINT16	no-units		
Status	3000	Status	1	UINT16	no-units		Unknown(0);Normal(1);Limp mode(2);Unknown(3);Unknown(4); Unknown(5);Unknown(6);Unknown (7);Unknown(8);Unknown(9);Prog Set Update via buttons(10);Prog Set Update via IrDA(11); Prog Set Update via COM2(12)
Meters	4002	Vab	2	FLOAT	volts		
	4004	Vbc	2	FLOAT	volts		
	4006	Vca	2	FLOAT	volts		
	4010	Van	2	FLOAT	volts		
	4012	Vbn	2	FLOAT	volts		
	4014	Vcn	2	FLOAT	volts		
	4231	Min Van	2	FLOAT	volts		
	4233	Min Vbn	2	FLOAT	volts		
	4235	Min Vcn	2	FLOAT	volts		
	4241	Min Vab	2	FLOAT	volts		
	4243	Min Vbc	2	FLOAT	volts		
	4245	Min Vca	2	FLOAT	volts		
	4296	Max Van	2	FLOAT	volts		
	4298	Max Vbn	2	FLOAT	volts		

Category	Modbus TCP Register	Description	Register Count	Type ID	Units	Writable	Possible Values
	4300	Max Vcn	2	FLOAT	volts		
	4306	Max Vab	2	FLOAT	volts		
	4308	Max Vbc	2	FLOAT	volts		
	4310	Max Vca	2	FLOAT	volts		
	4497	Phase Angle Vab	2	FLOAT	degrees-phase		
	4499	Phase Angle Vbc	2	FLOAT	degrees-phase		
	4501	Phase Angle Vca	2	FLOAT	degrees-phase		
	5002	Ia	2	FLOAT	amperes		
	5004	Ib	2	FLOAT	amperes		
	5006	Ic	2	FLOAT	amperes		
	5010	In	2	FLOAT	amperes		
	5250	Demand Ia	2	FLOAT	amperes		
	5252	Demand Ib	2	FLOAT	amperes		
	5254	Demand Ic	2	FLOAT	amperes		
	5014	Peak Demand Ia	2	FLOAT	amperes		
	5016	Peak Demand Ib	2	FLOAT	amperes		
	5018	Peak Demand Ic	2	FLOAT	amperes		
	5338	Phase Angle Ia	2	FLOAT	degrees-phase		
	5340	Phase Angle Ib	2	FLOAT	degrees-phase		
	5342	Phase Angle Ic	2	FLOAT	degrees-phase		
	6006	Real Power	2	FLOAT	watts		
	6070	Apparent Power	2	FLOAT	volt-amperes		
	6134	Reactive Power	2	FLOAT	volt-amperes-reactive		
	6220	PF Apparent	2	FLOAT	power-factor		
	6460	Max Demand Positive PF	2	FLOAT	power-factor		
	6462	Max Demand Negative PF	2	FLOAT	power-factor		
	6464	Min Demand Positive PF	2	FLOAT	power-factor		
	6466	Min Demand Negative PF	2	FLOAT	power-factor		
	6468	Avg Positive PF	2	FLOAT	power-factor		
	6470	Avg Negative PF	2	FLOAT	power-factor		
	7004	Forward Real Energy	2	FLOAT	watt-hours		
	7006	Reverse Real Energy	2	FLOAT	watt-hours		
	7008	Net Real Energy	2	FLOAT	watt-hours		

Category	Modbus TCP Register	Description	Register Count	Type ID	Units	Writable	Possible Values
	7010	Leading Reactive Energy	2	FLOAT	volt-ampere-reactive-hours		
	7012	Lagging Reactive Energy	2	FLOAT	volt-ampere-reactive-hours		
	7014	Net Reactive Energy	2	FLOAT	volt-ampere-reactive-hours		
	7016	Apparent Energy	2	FLOAT	volt-ampere-hours		
	7220	Demand Forward Watts	2	FLOAT	watts		
	7222	Peak Demand Forward Watts	2	FLOAT	watts		
	7262	Demand Reverse Watts	2	FLOAT	watts		
	7264	Peak Demand Reverse Watts	2	FLOAT	watts		
	7303	Demand Lagging VARs	2	FLOAT	volt-amperes-reactive		
	7305	Peak Demand Lagging VARs	2	FLOAT	volt-amperes-reactive		
	7345	Demand Leading VARs	2	FLOAT	volt-amperes-reactive		
	7347	Peak Demand Leading VARs	2	FLOAT	volt-amperes-reactive		
	7387	Demand VAs	2	FLOAT	volt-amperes		
	7389	Peak Demand VAs	2	FLOAT	volt-amperes		
	7628	Total Reactive Energy	2	FLOAT	volt-ampere-reactive-hours		
	7679	Total Real Energy	2	FLOAT	watt-hours		
	11000	Frequency	2	FLOAT	hertz		
	11022	Min Frequency	2	FLOAT	hertz		
	11027	Max Frequency	2	FLOAT	hertz		
Controls	2206	Reset Energy	1	INT16	no-units	Yes	
	2232	Reset All Min/Max Values	1	INT16	no-units	Yes	