

# Potential Vulnerability

## CGLine+ connection to CGVision

<b>Date:</b>	Oct 15, 2019
<b>Subject:</b>	Potential vulnerability with CGLine+ when connected to CGVision
<b>Severity rating:</b>	High
<b>Product:</b>	CGLine+ (when connected to CGVision)
<b>Affected version:</b>	CGLine+ Web Controller: up to version Z1000.H CGVision: versions 6.02 to 6.40

### General Information

Eaton performs regular cybersecurity assessments of its applications and implements improvements to security vulnerabilities identified.

Based on these assessments, Eaton is aware of a potential vulnerability in the CGLine+ Web Controller when connected to the supervision software CGVision. This affects all CGLine+ Web Controllers up to software version Z1000.H in combination with the CGVision software version 6.02 up to 6.40. CGLine+ Web Controllers that are not connected to CGVision are not affected.

### Recommendation

A new version of the CGLine+ Web Controller (Version Z1000.J) is already available. Eaton recommends all customers to install this new software version. Please contact the EATON service hotline ([kundendienst@ceag.de](mailto:kundendienst@ceag.de) or +49 2921 69493) to get the newest firmware.

Another new version of the CGLine+ Web Controller and CGVision software are scheduled for release in November 2019. Customers will be notified immediately of this new release.

For additional information or a list of other issues that have been reported and resolved, please visit our Cybersecurity web site [www.eaton.com/cybersecurity](http://www.eaton.com/cybersecurity), or you can contact us at [CybersecurityCOE@eaton.com](mailto:CybersecurityCOE@eaton.com).

### Best Practices

Eaton recommends that you follow the best practices listed below when deploying this product. Additional guidelines for securely deploying our products are outlined in our whitepaper, *Cybersecurity Considerations for Electrical Distribution Systems*.

- Always install the latest updates from Eaton
- Protect access to physical ports and cabinets
- Deactivate unused ports/services
- Change passwords regularly
- Always use least privilege
- Whitelist network access if applicable
- Install products in safe environments only as documented



Eaton  
1000 Eaton Boulevard  
Cleveland, OH 44122  
United States  
Eaton.com

© 2017 Eaton  
All Rights Reserved  
Printed in XXX  
Publication No. BRXXXXXXXXX / XXX  
July 2017

Follow us on social media to get the latest product and support information.



Eaton is a registered trademark.

All other trademarks are property of their respective owners.