



中国节能产品认证证书

证书编号: CQC17701181700

申请人名称及地址: 伊顿电源(上海)有限公司
中国(上海)自由贸易试验区日滨路76号B5部位

品 牌: EATON

制造商名称及地址: 山特电子(深圳)有限公司
深圳市宝安区72区宝石路8号

生产企业名称及地址: 山特电子(深圳)有限公司
深圳市宝安区72区宝石路8号

产 品 名 称: 不间断电源

系 列/规 格/型 号: 见附件

认 证 模 式: 产品检验+初始工厂检查+获证后监督

产品标准/技术要求: CQC3108-2011

上述产品符合 CQC31-461234-2009 认证规则的要求, 特此发证。

证 书 有 效 期: 2017年11月20日至2020年11月20日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。



主任:



中国质量认证中心



CHINA CERTIFICATE FOR ENERGY CONSERVATION PRODUCT

CERTIFICATE NO.: CQC17701181700

NAME AND ADDRESS OF THE APPLICANT:	Eaton Power Quality (Shanghai) Co., Ltd. No.8 Bao shi Rd,Block 72 Bao'an District,Shenzhen,Guangdong 518101,China
BRAND NAME:	EATON
NAME AND ADDRESS OF THE MANUFACTURER:	Santak Electronic (Shenzhen) Co.,Ltd No.8 Bao shi Rd,Block 72 Bao'an District,Shenzhen,Guangdong 518101,China
NAME AND ADDRESS OF THE FACTORY:	Santak Electronic (Shenzhen) Co.,Ltd No.8 Bao shi Rd,Block 72 Bao'an District,Shenzhen,Guangdong 518101,China
PRODUCT NAME:	Uninterruptible Power Supply
PRODUCT MODEL AND SPECIFICATION:	See Appendix
TYPE OF CERTIFICATION SCHEMES:	Product Testing + Initial Factory Inspection + Follow up Factory Inspection
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS:	CQC3108-2011

This is to certify that the above mentioned product(s) complies with the requirements of CQC31-461234-2009 .

Valid from: Nov.20,2017

Valid until: Nov.20,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国节能产品认证证书

附录
APPENDIX

证书编号: CQC17701181700

第 1 页 共 2 页

Page 1 of 2

纸号: 121898

型号	交流输入	逆变输出	系统容量	外形尺寸(mm)
93E 100kVA	AC380V,3Φ+N+PE, 50/60Hz,161A	AC380V,3Φ+N+PE, 50/60Hz,152A	100kVA /90kW	1880×600× 820
93E 120kVA	AC380V,3Φ+N+PE, 50/60Hz,200A	AC380V,3Φ+N+PE, 50/60Hz,182A	120kVA /108kW	1880×600× 820
93E 160kVA	AC380V,3Φ+N+PE, 50/60Hz,262A	AC380V,3Φ+N+PE, 50/60Hz,243A	160kVA /144kW	1880×600× 820
93E 200kVA	AC380V,3Φ+N+PE, 50/60Hz,323A	AC380V,3Φ+N+PE, 50/60Hz,304A	200kVA /180kW	1880×600× 820

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:



中国质量认证中心



中国节能产品认证证书

附录
APPENDIX

证书编号: CQC17701181700

第 2 页 共 2 页

Page 2 of 2

纸号: 121898

型号	交流输入	逆变输出	系统容量	外形尺寸(mm)
93E 300kVA	AC380V,3Φ+N+PE, 50/60Hz,484A	AC380V,3Φ+N+PE, 50/60Hz,456A	300KVA/270KW	1880×1600×820
93E 400kVA	AC380V,3Φ+N+PE, 50/60Hz,645A	AC380V,3Φ+N+PE, 50/60Hz,608A	400KVA/360KW	1880×1600×820
93E 500kVA	AC380V,3Φ+N+PE, 50/60Hz,826A	AC380V,3Φ+N+PE, 50/60Hz,760A	500kVA/450kW	1880×1600×820

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:



中国质量认证中心