



CB TEST CERTIFICATE

Ref. Certificate No.

NL-14740

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	moulded-case circuit-breaker		
Applicant:	Cutler-Hammer Technology & Quality Center	170 Industry Drive Pittsburg PA	United States of America
Manufacturer:	Cutler-Hammer Technology & Quality Center	170 Industry Drive Pittsburg PA	United States of America
Factory:	Eaton Corporation Electrical Group	Tuscarwas Road PA 15009, BEAVER	United States of America
Rating and principal characteristics:	3 / 4 pole Ie = 250, 300, 320, 350, 400, 500, 600, 630 A Ue = 240 Vac, Ics = 85 kA, Icu = 85 kA Ue = 415 Vac, Ics = 50 kA, Icu = 50 kA Ue = 250 Vdc, Ics = 22 kA, Icu = 22 kA Uimp = 8 kV, Ui = 690 V		
Trade mark (if any):	CUTLER-HAMMER		
Model/Type reference:	L630S		
Additional information:	Testing procedure: WMT		
Sample of product tested to be in conformity with IEC:	60947-2(ed.4)		
Test Report Ref. No:	2038004.51 (90 pages)		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



Signed by: F.S.Strikwerda

Date of issue: 2008-08-29