

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180827- E7819  
**Report Reference** E7819-20090703  
**Issue Date** 2018-AUGUST-27

**Issued to:** EATON  
1000 CHERRINGTON PKWY  
MOON TOWNSHIP PA 15108-4312

**This is to certify that  
representative samples of**

CIRCUIT BREAKERS, MOLDED CASE AND CIRCUIT-  
BREAKER ENCLOSURES

Power Defense Insulated Case Circuit Breakers, PD-NF  
and Series NRX-NF Frame.

100% rated, enclosure size 22 x 23 x 20 in. (76.5 Sq. in  
vent total: 31.88 below cassette and 44.62 above cassette).

Breaker is suitable for reverse feed.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 489, Molded-Case Circuit Breakers, Molded-Case  
Switches and Circuit-Breaker Enclosures

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

