

333 Pfingsten Road
Northbrook, Illinois 60062-2096
United States Country Code (1)
(847) 272-8800
FAX No. (847) 272-8129
<http://www.ul.com>



March 28, 2003



Cutler-Hammer
Technology & Quality Center
170 Industry Drive
RIDC Park West
Pittsburgh, PA 15275

Subject: UL Listing and Recognition of Cutler-Hammer 600 Volt Molded-
Case Circuit Breakers and Low-Voltage AC Power Circuit
Breaker Products

To whom it may concern:

This letter verifies that all Cutler-Hammer UL Listed Molded-Case Circuit Breakers and Low-Voltage AC Power Circuit Breaker have been certified by Underwriters Laboratories.

These Devices Conform to UL489 Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures and UL1066 Low-Voltage AC and DC Power Circuit Breakers Used in Enclosures respectfully

Please do not hesitate to contact me if I may be of further service to you.

Regards,

A handwritten signature in black ink that reads 'Michael S. Mayes'.

Michael S. Mayes (Ext.42996).
Lead Engineering Associate
Conformity Assessment Services
Ph.: 847-664-2996

Reviewed by:

A handwritten signature in black ink that reads 'Jeffrey H. Hidaka'.

Jeffrey H. Hidaka (Ext.42963)
Associate Managing Engineer
Conformity Assessment Services
Ph.: 847-664-2963