



Certificate of Compliance

Certificate: 70205993

Master Contract: 163545 (043556)

Project: 70205993

Date Issued: 2018-12-12

Issued to: **Eaton Corporation**
1000 Cherrington Pkwy
Moon Township, Pennsylvania 15108
USA

Attention: **Lou Grahor**

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Zhibin Li*
Zhibin Li

PRODUCTS

CLASS - C143201 - CIRCUIT BREAKERS-Moulded Case Type

Moulded case circuit breaker, Type PDG3, PDF3 and PDD3, rated 100-400A, 600V ac, 250Vdc, 2, 3, or 4-pole. Supplied with thermal magnetic (PD3A) or electronic trip units (PRX series).

Notes:

1. Type PDG3, PDF3 and PDD3 Frame circuit breakers may be marked with the following interrupting ratings.

Type	240V ac	480V ac	600V ac	250V dc
PDG3xF/PDF3xF/PDD3xF	35	25	14	10
PDG3xG/PDF3xG/PDD3xG	65	35	18	10
PDG3xK/PDF3xK/PDD3xK	85	50	25	10
PDG3xM/PDF3xM/PDD3xM	100	65	35	22
PDG3xN/PDF3xN/PDD3xN	150	85	50	22
PDG3xP/PDF3xP/PDD3xP	200	100	65	22

2. The thermal magnetic trip unit, PD3A and Electronic trip unit, PXR series are described in CSA report 1688126, project 70207145)

APPLICABLE REQUIREMENTS



Certificate: 70205993

Project: 70205993

Master Contract: 163545

Date Issued: 2018-12-12

CSA Std C22.2 No. 5

Moulded Case Circuit Breakers, Moulded Case Switches, and
Circuit Breaker Enclosures



Supplement to Certificate of Compliance

Certificate: 70205993

Master Contract: 163545 (042193_0_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70205993	2018-12-12	Original certification of Mold case breaker, Type PDG3A, rated 400A, 600Vac max.