



Certificate of Compliance

Certificate: 1688126 Master Contract: 163545 (043556)

Project: 70207145 Date Issued: 2018-12-12

Issued to: Eaton Corporation
1000 Cherrington Pkwy
Moon Township, Pennsylvania 15108
USA
Attention: Lou Grahor

The products listed below are eligible to bear the CSA Mark shown



Issued by: Zhibin Li
Zhibin Li

PRODUCTS

CLASS - C143201 - CIRCUIT BREAKERS-Moulded Case Type

- Moulded case circuit breaker, Type LG Frame, Types LGE, LGS, LGH, 250-600A, 600V ac, 2, 3, or 4-pole. Supplied with thermal magnetic or electronic trip units. Type LHH, 125-400A, 600V ac, 3-pole.

Notes:

1. Type LG Frame circuit breakers may be marked with the following interrupting ratings.

Type	Frequency, HZ	240V ac	480V ac	600V ac	250V dc	600V dc
LGE	50/60	65	35	18	22	-
LGS	50/60	85	50	25	22	-
LGH	50/60	100	65	35	42 or 50	-
LGE-C	50/60	65	35	18	22	-
LGS-C	50/60	85	50	25	22	-
LGH-C	50/60	100	65	35	42 or 50	-
LHH	50/60	100	65	35	42 or 50	-
LGH-DC	-	-	-	-	42 or 50	65
LGS-DC	-	-	-	-	22	50
LGE-DC	-	-	-	-	22	35



Certificate: 1688126
Project: 70207145

Master Contract: 163545
Date Issued: 2018-12-12

2. Suffix letter C may be added to type designations LGE, LGS and LGH to denote suitable for 100% rating.

- Moulded case circuit breaker, Type PDG3, PDF3 and PDD3, rated 250-600A, 600V ac, 250Vdc, 2, 3, or 4-pole; thermal magnetic trip unit, (PD3A and PD3B) and electronic trip units (PXR series).

Notes:

1. Type PDG3, PDF3 and PDD3 Frame circuit breakers may be marked with the following interrupting ratings.

Type	240V ac	480V ac	600V ac	250V dc
PDG3xF/PDF3xF/PDD3xF	35	25	14	22
PDG3xG/PDF3xG/PDD3xG	65	35	18	22
PDG3xK/PDF3xK/PDD3xK	85	50	25	22
PDG3xM/PDF3xM/PDD3xM	100	65	35	42
PDG3xN/PDF3xN/PDD3xN	150	85	50	42
PDG3xP/PDF3xP/PDD3xP	200	100	65	42

CLASS 1437 01 – CIRCUIT BREAKERS - Accessories

Circuit breaker accessories, wire connecting terminal assembly kits, Cat. Nos.: TA631LK, T631LK, TA632LK, T632LK, TA350LK and T350LK, with prefixes 1, 2, 3 or 4, for use with submitter's CSA Certified Type LG Frame circuit breakers.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 5 Moulded Case Circuit Breakers, Moulded Case Switches, and Circuit Breaker Enclosures



Supplement to Certificate of Compliance

Certificate: 1688126

Master Contract: 163545 (042193_0_000)

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70207145	2018-12-12	Covers additional Moulded case circuit breaker, Type PDG3, PDF3 and PDD3, rated 250-600A, 600V ac, 250Vdc, 2, 3, or 4-pole; Also covers the thermal magnetic trip unit, (PD3A and PD3B) and electronic trip units (PXR series).
2735157	2014-07-08	Addition of IlSCO lug D3722
2437423	2011-11-21	Addition of LHH circuit breaker and DC ratings for LG frame
2238804	2009-12-01	To cover the addition of circuit breaker accessories, wire connecting terminal assembly kits
1979832	2008-03-20	LT solid state trip unit with maintenance mode/instantaneous settings
1846047	2007-01-26	LT Solid State Trip Unit
1688126	2006-03-22	Moulded Case Circuit breakers Legacy File 43556