



Certificate of Compliance

Certificate: 2434983 **Master Contract:** 163545 (LR 43556)
Project: 70209791 **Date Issued** 2018-12-18
Issued to: **Eaton Corporation**
1000 Cherrington Pkwy
Moon Township, Pennsylvania 15108
USA
Attention: Lou Grahor

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Zhibin Li*
Zhibin Li

PRODUCTS:

CLASS - C143201 - CIRCUIT BREAKERS-Moulded Case Type

Circuit breakers, moulded case type, R-frame, Series C, Type RD, RGH, RDC and RGC, 800-1600A, 1000-2000A and 1200-2500A and Type CRD and CRDC, 800-1600A and 1000-2000A, 3- and 4-pole, 600V ac, interchangeable solid state trip. Type RD, DC, 1600-3000A, 600V dc max, 3 poles in series.

Notes:

1. These circuit breakers may be marked with the following high current interrupting ratings in RMS symmetrical kilo amps:

<u>Type</u>	<u>Poles</u>	<u>Volts ac (50/60Hz)</u>		
		<u>240</u>	<u>480</u>	<u>600</u>
RD, CRD, RGH	3	125	65	50
RDC, CRDC, RGC	3	200	100	65

Circuit breakers, moulded case type, Type PDG6M, PDG6N, PDG6P, PDF6M, PDF6N and PDF6P with a maximum rating of 2500 A, 600 V ac in two, three and four pole configuration, fixed and drawout mounted; Breaker trip unit, type PD6 for use with PDG6M, PDG6N, PDG6P, PDF6M, PDF6N and PDF6P breakers.

Notes:



Certificate: 2434983
Project: 70209791

Master Contract: 163545
Date Issued: 2018-12-18

1. Those breakers may be marked with high interrupting rating as following:

<u>Breaker Type</u>	<u>Interrupting Capacity (kA)</u>			
	<u>Frequency (Hz)</u>	<u>240 V ac</u>	<u>480 V ac</u>	<u>600 V ac</u>
PDG6M, PDF6M	50/60	125	65	35
PDG6N, PDF6N	50/60	150	85	50
PDG6P, PDF6P	50/60	200	100	65

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 5 - Moulded Case Circuit Breakers



Supplement to Certificate of Compliance

Certificate: 2434983

Master Contract: 163545 (042193_0_000)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70209791	2018-12-18	Update report 2434983 to cover additional breakers, PDG6, PDF6 series with maximum rating of 2500 A, 600 V ac; also cover PD6 trip unit.
70149904	2017-09-12	Update report 2434983 to cover addition of Type RGHC, RGCC and E2R circuit breakers
70032435	2015-06-02	Addition of RD-DC
2434983	2011-11-28	Report Updating per issued FIR. Addition of Types RGH and RGC