



中国国家强制性产品认证证书

证书编号: 2008010307312738

委托人名称、地址

伊顿电气集团

1000 Cherrington Parkway Moon Township, PA 15108, USA

生产者(制造商)名称、地址

伊顿电气集团

1000 Cherrington Parkway Moon Township, PA 15108, USA

生产企业名称、地址

伊顿电气 比佛工厂

One Tuscarwas Road, Beaver, PA15009, USA

产品名称和系列、规格、型号

塑料外壳式断路器

L630C,HMCPLX;详情见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2019 年 12 月 16 日 有效期至: 2024 年 12 月 16 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2008 年 12 月 12 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询

经中国合格评定国家认可委员会认可 CNAS C001-P



主 任:

陆梅



中国质量认证中心

<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

Q 2490889



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2008010307312738

NAME AND ADDRESS OF THE APPLICANT

Eaton Electrical Inc.
1000 Cherrington Parkway Moon Township, PA 15108, USA

NAME AND ADDRESS OF THE MANUFACTURER

Eaton Electrical Inc.
1000 Cherrington Parkway Moon Township, PA 15108, USA

NAME AND ADDRESS OF THE FACTORY

Eaton Electrical Inc. Beaver
One Tuscarwas Road, Beaver, PA15009, USA

PRODUCT NAME, MODEL AND SPECIFICATION

Molded case circuit breaker
L630C,HMCPLX;See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Dec.16,2019

Valid until: Dec.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Dec.12,2008

The certificate information is available through CNCA's website: www.cnca.gov.cn

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

<http://www.cqc.com.cn>

Section 9, No. 188, Nanshuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666

Q 2490889



中国国家强制性产品认证证书

附录

证书编号: 2008010307312738

第 1 页 共 2 页

纸 号: 2490889

L630C, HMCPLX;

U_i : 690V

U_{imp} : 8kV;

U_e : AC240V, AC415V, AC690V 和 DC250V(仅适用于热磁式);

I_n : 250A, 300A, 320A, 350A, 400A, 500A, 600A, 630A(热磁式),
250A, 400A, 600A, 630A(电子式);

过电流脱扣器类型: 热磁式, 电子式;

$I_{cs}=I_{cu}=200kA$ (AC240V);

$I_{cs}=I_{cu}=100kA$ (AC415V);

$I_{cs}=I_{cu}=42kA$ (DC250V, 仅热磁式);

$I_{cs}=15kA$, $I_{cu}=30kA$ (AC690V);


使用类别: A 类;

极数: 3P, 4P (L630C), 3P (HMCPLX);


适用频率: 50/60Hz;

适用于隔离;

直流接线方式:



3P接线方式



4P接线方式

型号解释:

注: 此附录与证书同时使用时有效。



主任:

陆楠



中国质量认证中心




中国国家强制性产品认证证书

附录

第 2 页 共 2 页

证书编号: 2008010307312738

纸号: 2490889



注: 此附录与证书同时使用时有效。



主任:

陆梅



中国质量认证中心