



Seismic qualified



Eaton's equipment identified below was tested for seismic withstand capability and tested in accordance with the combined requirements specified in the International Building Code, the California Building Code, and the Uniform Building Code.

As required by the codes, the equipment demonstrated its ability to function after the seismic tests. The seismic capability of the equipment exceeds the worst-case required levels, as illustrated in the figure below.



William V. Joerger, S.E.
ISAT

3RD PARTY TEST ENGINEER IN CHARGE

For interpretation of testing data,
refer to Eaton
Publication SA12501SE

TESTED BY
Wyle Laboratories
April, 2013-70566R12