



TIME-CURRENT CHARACTERISTIC CURVES

MINIMUM MELT
8.3 kV ELF™ DROPOUT FUSE

Tests made at LOW Volts ac at HIGH pf at 25°C with no initial load

Standards used as basis for data: ANSI C37.47-1991 (R1992)

MINIMUM TEST POINTS PLOTTED SO VARIATIONS SHOULD BE PLUS

THIS DRAWING WAS PRODUCED ON A CAD SYSTEM, ANY MANUAL REVISION WILL VOID IT.

| | | | |
|----------|--------|--------|---------------|
| DRAWN BY | DML | CHK'D | |
| DATE | 6-1-99 | DATE | |
| REPLACES | 11/96 | REV 09 | REG NO. 19018 |
| DWG NO. | 42 | 39106 | B 00 |

* - - - - - 50, 65 & 80 AMP FUSES ARE MADE UP OF 2 SMALLER UNITS OF EQUAL RATINGS IN A PARALLEL MOUNTING.

— — — — — 100 AMP FUSE IS MADE UP OF 3 SMALLER UNITS OF EQUAL RATING IN A PARALLEL MOUNTING.

Reference Data
R240-91-42
Page 1 of 2



TIME-CURRENT CHARACTERISTIC CURVES

MAXIMUM CLEAR
8.3 kV ELF™ DROPOUT FUSE

Tests made at HIGH Volts ac at LOW pf at 25°C with no initial load

Standards used as basis for data: ANSI C37.47-1991 (R1992)

MINIMUM TEST POINTS PLOTTED SO VARIATIONS SHOULD BE MINUS

THIS DRAWING WAS PRODUCED ON A CAD SYSTEM, ANY MANUAL REVISION WILL VOID IT.

| | | | |
|----------|--------|--------|---------------|
| DRAWN BY | DML | CHK'D | |
| DATE | 6-1-99 | DATE | |
| REPLACES | 11/96 | REV 09 | REG NO. 19018 |
| DWG NO. | 42 | 39106 | B 00 |

* - - - - - 50, 65 & 80 AMP FUSES ARE MADE UP OF 2 SMALLER UNITS OF EQUAL RATINGS IN A PARALLEL MOUNTING.

— — — — — 100 AMP FUSE IS MADE UP OF 3 SMALLER UNITS OF EQUAL RATING IN A PARALLEL MOUNTING.

Reference Data
R240-91-42
Page 2 of 2