


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Luminaire for emergency lighting with LED light source
Name and address of the applicant	Cooper Securite SAS Parc Européen d'Entreprises II Rue Beethoven – BP 10184 63204 RIOM Cedex France
Name and address of the manufacturer	Cooper Csa S.r.l. Via San Bovio,3 – Edificio Y 20090 Segrate (MI) Italy
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 SC Cooper Industries Romania SRL Zona Industrială Vest Strada III, Nr. 12 310510 Arad Romania
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	220-240 V, 50/60 Hz, LED modules, autonomy 60–180 minutes. Class II; IP40 or IP65 Refer to Test Report for the list of rating covered by the certificate
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NEXI, NEXI-D
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 The luminaire can be mounted on the recessed ceiling / wall by the means of accessory: NEXI-RB Recessed wall box (dimension 277 x 100 mm) NEXI- FC Kit Recessed ceiling (dimension 272 x 95 mm). This certificate replaces certificate NL-49298 which we herewith declare invalid
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-2-22:2014  National differences: EU Group Differences 3505914.50
As shown in the Test Report Ref. No. which forms part of this Certificate	

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands