

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0806

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

CAB482CS Addressable Type A Red Light Flash Ceiling VAD with Short Circuit Isolator (Red Body)

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

Eaton Electrical Systems Ltd
Wheatley Hall Road
Doncaster
South Yorkshire
DN2 4NB
United Kingdom

Eaton Electrical Products Ltd
Llantarnam Park
Cwmbran
South Wales
NP44 3AW
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-23:2010 - Visual Alarm Devices
EN 54-17:2005 - Short Circuit Isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 15 July 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager

Date of First Issue: 15 July 2020

Date of Issue: 15 July 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0806

CAB482CS Addressable Type A Red Light Flash Ceiling VAD with Short Circuit Isolator (Red Body)

Notes:

1. Meets the requirements of EN 54-23 at the following:

- Category C-3.0-7.5 + C-3.0-2.5
- Flash rate 0.5Hz or 1Hz
- Synchronisation
- Red LED
- Clear Lens

Bases:

Shallow Base



P Halligan, Certification Manager,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 15 July 2020

Date of issue: 15 July 2020

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie