

# BRE Global Ireland

## Notified Body No. 2831

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

### 2831-CPR-F0803

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### **CAB482WD Addressable Type A/B Red Light Flash Wall VAD with Short Circuit Isolator (Red Body)**

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

**Eaton Electrical Systems Limited**  
Wheatley Hall Road  
Doncaster  
South Yorkshire  
DN2 4NB  
United Kingdom

**Eaton Electrical Products Ltd**  
Llantarnam Park  
Cwmbran  
South Wales  
NP44 3AW  
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

#### **EN 54-17: 2005 - Short Circuit Isolators** **EN 54-23: 2010 - Visual Alarm Devices**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 15 July 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 15 July 2020

Date of Issue: 15 July 2020

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

## BRE Global Ireland

### Notified Body No. 2831

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

T: +353 (0) 18824344

E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## APPENDIX to Certificate of constancy of performance: 2831-CPR-F0803

### CAB482WD Addressable Type A/B Red Light Flash Wall VAD with Short Circuit Isolator (Red Body)

#### Notes:

1. Meets the requirements of EN 54-23 at the following:

- Category W-2.4-7.5 + W-2.4-2.48
- Flash rate 0.5Hz or 1Hz
- Synchronisation
- Red LED
- Clear Lens

#### Bases:

Shallow Base (Type A)

Deep Base (Type B)



P Halligan, Certification Manager,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 15 July 2020

Date of issue: 15 July 2020

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)