

## DECLARATION OF PERFORMANCE

### No DoP0087

*Unique identification code of the product-type:*

Asserta Midi AS/M/S/9-60

---

*Intended use/es:*

Fire detection and fire alarm systems

---

*Manufacturer:*

Eaton Electrical Products Ltd, Llantarnam Park, Cwmbran, South Wales, NP44 3AW, United Kingdom

---

*Authorised representative:*

Not Applicable

---

*System/s of AVCP:*

System 1

---

*Harmonised standard/s:*

EN54-3:2001+A1:2002+A2:2006

---

*Notified body/ies:*

BRE Global Assurance (Ireland) Limited, DCU Alpha, Old Finglas Road, Glasnevin, Dublin, D11 KXN4,  
Ireland (2831-CPR-F1164)

---

*Declared performance/s:*

| Essential Characteristics   | Performance | Harmonized Technical Specification                    |
|---|-------------|---|
|   |             | EN54-3:2001 + A1:2002 + A2:2006                       |
| Performance under fire conditions                                     | Pass        | 4.2, 4.3, 5.2, 5.3, C.3.1, C.3.2, C.5.1, C.5.2, C.5.3 |
| Operational reliability   | Pass        | 4.4, 4.5, 4.6, 5.4, C4                                |
| Durability Of Operational Reliability, Temperature Resistance         | Pass        | 5.5, 5.7, 5.8, 5.9                                    |
| Durability Of Operational Reliability, Humidity Resistance            | Pass        | 5.8, 5.9  |
| Durability Of Operational Reliability, Corrosion Resistance           | Pass        | 5.11  |
| Durability Of Operational Reliability, Shock and Vibration Resistance | Pass        | 5.12 to 5.15  |
| Durability Of Operational Reliability, Electrical Stability           | Pass        | 5.16  |
| Durability Of Operational Reliability, Resistance To Ingress          | Pass        | 5.17  |

*The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulations (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.*

*Signed for an on behalf of the manufacturer by:*

*Name:* Mr Philip Williams (Approvals Manager)

*Signed:* 

*Place:* Cwmbran

*Date:* 17<sup>th</sup> August 2020