



Powering Business Worldwide

Eaton Electrical Products Ltd  
Llantarnam Park, Cwmbran,  
South Wales NP44 3AW, UK  
Tel: +44 (0)1633 628500  
Fax: +44 (0)1633 866346  
Email: [FulleonCS@eaton.com](mailto:FulleonCS@eaton.com)  
Web: [www.cooperfulleon.com](http://www.cooperfulleon.com)

## DECLARATION OF CONFORMITY

We, **Eaton Electrical Products Ltd,  
Llantarnam Park,  
Cwmbran, South Wales,  
United Kingdom.  
NP44 3AW**

*declare under our sole responsibility that the product(s)*

**Asserta Mini 9-60Vdc**

**(for Fire Detection & Fire Alarm Systems)**

*Manufactured at the following site,*

**Eaton Electrical Products Ltd, Llantarnam Park, Cwmbran, South Wales, United Kingdom.  
NP44 3AW**

*is (are) in conformity with the following standard(s) or other normative document(s)*

**EN 61000-6-3:2007 + A1:2011 (EMC), EN 50130-4:2011 (EMC)**

**EN 50581:2012 (RoHS)**

*when used in the following applications & conditions:*

**Fire Detection & Alarm Systems**

*following the provisions of the directive(s):*

**2014/30 EU EMC**

**2011/65/EU RoHS**

20<sup>th</sup> April 2016

**Date of Declaration**

**Ian P Stokes, Technical Director**

Year of affixing the CE-marking: 2011

Registered in England No. 1342230. Registered Office: Jephson Court, Tancred Close, Royal Leamington Spa, Warwickshire. CV31 3RZ



Powering Business Worldwide

Eaton Electrical Products Ltd  
Llantarnam Park, Cwmbran,  
South Wales NP44 3AW, UK  
Tel: +44 (0)1633 628500  
Fax: +44 (0)1633 866346  
Email: [FulleonCS@eaton.com](mailto:FulleonCS@eaton.com)  
Web: [www.cooperfulleon.com](http://www.cooperfulleon.com)

## DECLARATION OF CONFORMITY

We, **Eaton Electrical Products Ltd,  
Llantarnam Park,  
Cwmbran, South Wales,  
United Kingdom.  
NP44 3AW**

*declare under our sole responsibility that the product(s)*

**Asserta Mini 230Vac**

**(for Fire Detection & Fire Alarm Systems)**

*Manufactured at the following site,*

**Eaton Electrical Products Ltd, Llantarnam Park, Cwmbran, South Wales, United Kingdom.  
NP44 3AW**

*is (are) in conformity with the following standard(s) or other normative document(s)*

**EN 61000-6-3:2007 + A1:2011 (EMC), EN 50130-4:2011 (EMC)**

**EN 50581:2012 (RoHS), EN60950-1:2006 + A1:A2:2013 (LVD)**

*when used in the following applications & conditions:*

**Fire Detection & Alarm Systems**

*following the provisions of the directive(s):*

**2014/30 EU EMC**

**2011/65/EU RoHS**

**2014/35 EU LVD**

20<sup>th</sup> April 2016

**Date of Declaration**

**Ian P Stokes, Technical Director**

Year of affixing the CE-marking: 2011

Registered in England No. 1342230. Registered Office: Jephson Court, Tancred Close, Royal Leamington Spa, Warwickshire. CV31 3RZ