#### **Eaton Electrical Products Ltd**

Llantarnam Park, Cwmbran South Wales, NP44 3AW Tel: +44 (0) 1633 628500 Fax: +44 (0) 1633 866346 Emai: <u>Firecustomerservices@eaton.com</u>

Web: www.eaton.com



# **DECLARATION OF PERFORMANCE**

## No DoP0284

Unique identification code of the product-type:		
BWEXTR230V		
Intended use/es:		
Fire detection and fire alarm systems		
Manufacturer:		
Eaton Electrical Products Ltd, Llantarnam Park, Cwmbran, South Wales, NP44 3AW, United Kingdom		
Authorised representative:		
Not Applicable		
System/s of AVCP:		
System 1		
Harmonised standard/s:		
EN54-18:2005		
Notified body/ies:		
Intertek Deutschland GmbH, Strangenstraße 1, 70771 Leinfelden-Echterdingen (0905-CPR-00449)		

#### **Eaton Electrical Products Ltd**

Llantarnam Park, Cwmbran South Wales, NP44 3AW Tel: +44 (0) 1633 628500 Fax: +44 (0) 1633 866346

Emai: Firecustomerservices@eaton.com

Web: www.eaton.com



### Declared performance/s:

Essential Characteristics	Performance	Harmonized Technical Specification EN54-18:2005
Response Delay (Response Time)	Pass	5.2
Performance under fire conditions	Pass	5.1.4
Operational Reliability	Pass	5.1.4
Durability of Operational Reliability, Temperature Resistance	Pass	5.3, 5.4
Durability of Operational Reliability, Vibration Resistance	Pass	5.8 to 5.11
Durability of Operational Reliability, Humidity Resistance	Pass	5.5, 5.6
Durability of Operational Reliability, Corrosion Resistance	Pass	5.7
Durability of Operational Reliability, Electrical Stability	Pass	5.2, 5.12

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulations (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for an on behalf of the manufacturer by:

Name: Mr Philip Williams (Approvals Manager)

Signed: PJ Www.

Place: Cwmbran Date: 17th August 2020